

 पुणे छावनी परिषद. भारत सरकार. रक्षा मंत्रालय गोलीबार मैदान पुणे 411001	 १९५० सत्यमेव जयते	Pune Cantonment Board Govt. of India, Ministry of Defence, Gollbar Maldan, Pune 411001	 Azadi Ka Amrit Mahotsav
"हर काग देश के नाग"			
दूरभाष संख्या 26452159-020 :		ई-मेल आई डी : ceopunecantf@gmail.com	
पत्र संख्या : FB/NOC/2025-26		Date : 03/06/2025	

To,  
 Z.V.M Multispecialty Hospital  
 2390, K.B Hidayatullah Road,  
 New Modikhana, Azam Campus,  
 Camp Pune - 411001.

**SUB: ISSUE OF FIRE NO OBJECTION CERTIFICATE.**

**Ref.: - 1. Letter Dated - 02/04/2025**

With Reference to your application dtd 02/04/2025 in respect of Fire NOC of Z.V.M Multispecialty Hospital 2390, K.B Hidayatullah Road, New Modikhana, Azam Campus, Camp Pune - 411001. Is being issued subject to following conditions.

1. Maintain Fire extinguisher in serviceable condition.
2. Maintain exit routes free of obstacles.
3. Fixed firefighting system may be kept serviceable at all the time.
4. A person from your establishment may be trained and be made responsible for its operation and serviceability.
5. Yearly inspection shall be carried out from Fire Brigade Department of Pune Cantonment Board.
6. Issue of NOC does not legalize unauthorized construction / a matter neither confirms any title right.
7. Issue of fire NOC does not absolve you from any unauthorized constructions / encroachments or violation of any nature from safety point of view.
8. This certificate is valid upto 1 year from the date of issue of this NOC. B' form to be submitted twice in a year for the validity of NOC.
9. The Fire brigade department of this office reserves the rights of periodical inspection of the premises and this NOC will be revoked immediately if there is any deviation of above conditions and from fire point of view in the premises.
10. In case if it is realized that this NOC has been obtained by misrepresentation of the facts or any violation of fire safety norms at any pointy of time is noticed subsequently the office of the Cantonment Board Pune reserves the rights to revoke the NOC without Notice.
11. Issuing authority retains the right to revoke NOC on failure of adherence of terms & conditions.

This is without prejudice to the right and interests of Cantonment Board, Pune

**Authority: - CBR No. - 12 dated 12/04/2021**

**CHIEF EXECUTIVE OFFICER  
 PUNE CANTONMENT BOARD,  
 (SUBRAT PAL)**

**PRINCIPAL & SUPERINTENDENT  
 Z.V.M. UNANI MEDICAL COLLEGE  
 & HOSPITAL, PUNE-01.**

Scanned with OKEN Scanner

# ESTEEM FIRE & SECURITY SERVICES

Fire Hydrant System, Fire Alarm System, Fire Sprinkler System & Fire Extinguishers  
Maharashtra Fire Services Licensed Agency | ISO 9001 : 2015 Certified Company



Tel. 022 - 25081155 Mobile No. : 9819868609 / 9869015155 | Email Id: esteemfire@gmail.com / efsfire@gmail.com

Head Off. : Shop No: 09, Bldg. No.218, Chandan Pride, Near Pant Nagar Police Station, Pant Nagar, Ghatkopar (East), Mumbai - 400 075.  
Branch Off: Plot No. 88/12, Arjunali Village, Near Padgha Toll Naka, Mumbai - Nashik Highway, Post Padgha, Taluka Bhiwandi - 421 101.

Ref: EFSS/JANUARY/2025  
To,  
Chief Fire Officer,  
Cantonment Fire Station,  
Shankar Sheth Road,  
Pune - 411001

## FORM - B

{{(see section 3 (3) and rule 4 (2))}}

Six monthly certificate to be given in every January and July by the owner or the occupier for compliance of the Fire Prevention and Life Safety Measures.

## CERTIFICATE

Certified that I / We have carried out inspection of the Fire Prevention and Life Safety Measures installed in the following building or premises, namely: -

**M/S. Z.V.M. MULTISPECIALITY HOSPITAL  
2390, K.B. HIDAYATULLAH ROAD, AZAM CAMPUS, PUNE - 411001**

I / We further certify that these installations in the above-mentioned buildings are maintained in good repair and efficient conditions during the period 1<sup>st</sup> July 2024 to 31<sup>st</sup> December 2024, as required under the provisions of the Maharashtra Fire Prevention and Life Safety Measures Act, 2006 (Mah-III of 2007). The details of the inspection of installations carried out by me / us are mentioned in the report appended herewith.

Place: Pune  
Date: 08/01/2024.

Signature and address of the Licensed Agency.  
FOR ESTEEM FIRE & SECURITY SERVICES.

**MOHAMM** Digitally signed by  
**ED AMIN** MOHAMMED  
**KHAN** AMIN KHAN  
Date: 2025.01.08  
20:16:11 +05'30'

Shop No. 09, Bldg. No. 218  
Chandan Pride, Pant Nagar,  
Ghatkopar (E), Mumbai - 400 075.  
License No. MFS-LA/RF-113 / RD-109.

*09/01/25*  
*6686*  
Fire Prevention Section  
Pune Cantonment Board

1 | Page

PAN No. APEPS2734N GSTIN No. 27APEPS2734N1ZE

PRINCIPAL & SUPERINTENDENT  
Z.V.M. UNANI MEDICAL COLLEGE  
& HOSPITAL, PUNE-01.

Scanned with OKEN Scanner

# ESTEEM FIRE & SECURITY SERVICES

Fire Hydrant System, Fire Alarm System, Fire Sprinkler System & Fire Extinguishers  
Maharashtra Fire Services Licensed Agency | ISO 9001 : 2015 Certified Company



Tel. 022 - 25081155 Mobile No. : 9819868609 / 9869015155 | Email Id: esteemfire@gmail.com / efssfire@gmail.com

Head Off. : Shop No: 09, Bldg. No.218, Chandan Pride, Near Pant Nagar Police Station, Pant Nagar, Ghatkopar (East), Mumbai - 400 075.  
Branch Off: Plot No. 88/12, Arjunali Village, Near Padgha Toll Naka, Mumbai - Nashik Highway, Post Padgha, Taluka Bhiwandi - 421 101.

## ANNEXURE TO FORM - B

Building / Premises Address:

**M/S. Z.V.M. MULTISPECIALITY HOSPITAL  
2390, K.B. HIDAYATULLAH ROAD, AZAM CAMPUS, PUNE - 411001**

This is to certify that the following Systems of above Building / Premises are maintained and is in good working condition.

Following are the details of the System / Equipment's.

Sr No.	Equipment's Details	Quantity
1	G.I Pipe 100 MM Jindal	45 Mtr
2	G.I Pipe 80 MM Jindal	25 Mtr
3	F.B.I Valve 2 way	01 Nos
4	Single Headed Hydrant Valve	07 Nos
5	Pressure Gauge	02 Nos
6	Canvas Hose Pipe with Male Female Coupling	07 Nos
7	Short Branch Nozzle	07 Nos
8	Single Door Hose Box	07 Nos
9	Hose Reel Drum Swinging type	07 Nos
10	Thermoplastic Hose Pipe with Shut off Nozzle	07 Nos
11	Booster Pump 10 HP	02 Nos
12	Fire Fighting Control Panel	01 Nos
13	Air Release Valve	02 Nos
14	Fire Alarm Panel 4 Zone	01 Nos
15	Smoke Detector with Base	30 Nos
16	Electronic Hooter	07 Nos
17	Manual Call Point	06 Nos
18	Fire Extinguisher Co2 type 4.5 kg capacity	03 Nos
19	Fire Extinguisher ABC type 6 kg capacity	10 Nos
20	Sprinkler 68 Degree	60 Nos
21	Pressure Switch	01 Nos

Place: Pune

Date: 08/01/2024.

Signature and address of the Licensed Agency.  
FOR ESTEEM FIRE & SECURITY SERVICES.

**MOHAMMED  
AMIN KHAN**

Digitally signed by  
MOHAMMED AMIN  
KHAN  
Date: 2025.01.08  
20:16:29 +05'30'

Shop No. 09, Bldg. No. 218  
Chandan Pride, Pant Nagar,  
Ghatkopar (E), Mumbai - 400 075.  
License No. MFS-LA/RF-113 / RD-109.

2 | Page

PAN No. APEPS2734N GSTIN No. 27APEPS2734N1ZE

Scanned with OKEN Scanner

PRINCIPAL & SUPERINTENDENT  
Z.V.M. UNANI MEDICAL COLLEGE  
& HOSPITAL, PUNE-01.